

Compliance Statement

No. 2019-320

Screened Channel, Class E_A/Category 6_A

Company

INFRASTONE LLC
5688 S 27th St.
WI 53221 Milwaukee
United States

Channel Identification (4 connector model)

Horizontal cable: Black Stone Cat6A Cable ID code: BSCA46A0000

Cords: Black Stone Cat6A Patch Cable ID code: BSAC/1/2/3/5M6A00-UXD06A-*-#

Plug: Black Stone Cat6A Plug ID code: UXD06A

Socket: Black Stone Cat6A Keystone Jack ID code: BSK/B/C/S/06/08/09/10

Wall Outlet: Black Stone Cat6A Wall Outlet ID code: OTX/E/S/Z

Patch Panel: Black Stone Cat6A Patch Panel ID code: BSPPC6A00/24/485

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

T924230-03, DANAK-19/20162

EC Cabling product ID


6009

CS valid until

1 May 2020

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 30 April 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

